

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7120-0992:122 Page 1 of 1

**CATEGORY:** Annunciators

**LISTEE:** Napco, 333 Bayview Avenue, Amityville, NY 11701  
Contact: \*Edmund Gregorian (631) 842-9400 ext. 270

**DESIGN:** Model FW-RA-LED remote multiplex annunciator. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** 20-19 VDC

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. For indoor use only.

**MARKING:** Listee's name, model number and UL label.

**APPROVAL:** Listed as annunciator panel for use with listee's separately listed compatible Model FW-C2Z, FW-C4Z and FW-C4EZ fire alarm control units (CSFM Listing No. 7165-0992:121).

**XLf:** 7120-1477:108

\*Rev. 06-12-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 12, 2002**

*Listing Expires **June 30, 2003***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager